

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater from a Force Main located at 285 Sugar Gum Lane in Pinehurst, North Carolina on August 20, 2017, of an estimated 9,696 gallons. The spill was due to Pipe failure. The spill was reported at 1:00 p.m. and continued for approximately 3 hours while repairs were made. The untreated wastewater entered Pinehurst Lake a tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on August 21, 2017 at 11:00 a.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.