

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater at 235 Lake Hills Road in Pinehurst, North Carolina on January 30, 2020 of an estimated 9,000 gallons. The spill was due to pipe failure. The spill was reported at 10:30 a.m. and continued for approximately 1 hour while repairs were made. The untreated wastewater entered Pinehurst Lake a tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on January 31, 2020 at 3:15 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.