

Notification of Discharge of Untreated Wastewater

Moore County Public Works had a discharge of untreated wastewater from a Force Main located at 285 Sugar Gum Lane in Pinehurst, North Carolina on June 29, 2020, of an estimated 21,440 gallons. The spill was due to Pipe failure. The spill was reported at 10:30 p.m. on the 29th and continued for approximately 1 ½ hours while an 11 ½' section of the pipe was replaced. The untreated wastewater entered Pinehurst Lake a tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on June 30, 2020 at 1:34 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.