

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater at Pump Station 10-3 located at 60 Sugar Gum in Pinehurst, North Carolina on January 30, 2020 of an estimated 77,196 gallons. The spill was due to pipe failure. The spill was reported at 2:00 p.m. and continued for approximately 4 hours while repairs were made. The untreated wastewater entered Pinehurst Lake a tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on January 31, 2020 at 3:15 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.