

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater from Lift Station 10-3 located at 60 Sugar Gum Lane in Pinehurst, North Carolina on December 23, 2018, of an estimated 1,000 gallons. The spill was due to Pump Station equipment failure. The spill was reported on December 23, 2018 at 6:15 p.m. and continued for approximately 1 hour while repairs were made. The untreated wastewater entered Pinehurst Lake a tributary to Horse Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on December 24, 2018 at 1:21 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.