

Notice of Discharge of Untreated Wastewater

Moore County Public Works had a discharge of untreated wastewater from Manhole 3-4-187 near the address of 300 Magnolia Road in Pinehurst, NC on September 14, 2022 of an estimated 200 gallons. The spill was caused by grease in the sewer line. The spill was reported at 10:00 a.m. and continued for approximately 1 hour until the main line was cleaned and the blockage was relieved. The untreated wastewater entered an unknown tributary to Joes Fork. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C. The NCDEQ was notified of the event on September 14, 2022 at 2:35 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.