

### **Notification of Discharge of Untreated Sewage**

Moore County Public Works had a discharge of untreated wastewater at 55 Surry Circle Drive North in Pinehurst, North Carolina on April 28, 2021, of an estimated 500 gallons. The spill was reported at 3 p.m. and continued for approximately 1/2 hour while repairs were made. The spill was due to roots in the line. The untreated wastewater entered an unknown tributary of Watson Lake and Aberdeen Creek. This notice is required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on April 30, 2021 at 8:30 a.m. and is reviewing the matter. For more information contact Moore County Public Works at 910-947-6315.