

### **Notification of Discharge of Untreated Wastewater**

Moore County Public Works had a discharge of untreated wastewater from Manhole N-1-A located off 501 below the traffic circle in Pinehurst, North Carolina on April 9, 2018, of an estimated 3,500 gallons. The spill was due to roots and debris in the line. The spill was reported at 12:20 p.m. and continued for approximately 2 hours while repairs were made. The untreated wastewater entered Aberdeen Creek a tributary to Drowning Creek. This notice was required by North Carolina General Statutes Article 21, Chapter 143.215C.

The NCDEQ was notified of the event on April 9, 2018 at 3 p.m. and is reviewing the matter. For more information contact Moore County Public Works at (910) 947-6315.